Cell : 9731374050
9060945255

SRI SAIRAM ELECTRICAL SERVICES

SERVICE IS OUR MOTO
(Government Licensed Class I Electrical Contractors & Service Engineers)
No. 2, Opp. Anjeneya Temple, Balaji Nagar, Ittmadu, Bangalore - 560 085.
E-mail : srisairam.es@gmail.com

TEST REPORT FOR TRANSFORMER OIL

Filt Date: 03/06/2018
Due Date: 02/06/2019

M/S AEE BBMP
J.P.Park Mujicad fountain Mathikere, Bangalore

System : 400 KVA Power Transformers

Transformer Details:

MAKE	VOLTECH		QTY of Oil	450 Ltrs
SL NO	GWZ002V/415		Ratio	11/433 KVA
RATING	400 Kva		Year of Mfg	2010

Results as per IS 335-1983

BDV Test Settings:

Gap Setting : 2.5mm
Temperature : Ambient
Frequency : 50 Cycles

BDV Test Results

Before Filtration : Tripped at 28 KV

After Filtration : Withstood at 50 KV for 60 Sec/80KV

Acidity Test Results : 0.1 mgm/KOH/gm

Standard Used:

SL NO	Nomenclatures	Make	Inst No	Traceability	Validity
1	Oil Test Kit	VI Power	2861247	EIC	Oct - 2018

Remarks: Transformer Oil Tested Good

Tested By	For Customer	For Sri Sai Ram Electrical Services
Engineer	Representative	M.V. Jayaram Partner